

Luminosity Calorimeter Technologies

- •SiW Silicon-tungsten sampling calorimeter (current Si tech)
- •Quartz Fiber Cerenkov longitudinal sampling (CMS HF)
- •Gas Cerenkov Cerenkov longitudinal sampling (new)
- •Parallel Plate Avalanche Ch gas sampling (current)
- •PbWO₄ Continuous scintillating (CMS ECAL)



The Problem

Bunch crossing (warm)
 1.4 ns

• (cold) 337 ns

Radiation dose ~100 MRad/y

Pairs produced / crossing ~ 200 TeV

<E> ~ 4 GeV

<x,y> ~ several cms


- Must see 250 GeV Bhabha e+e-
- Must veto 2-gamma background events



IP background calculation:

Takashi Maruyama, SLAC

e+ e- Pairs from e+ e- Collisions




20 April 2004

John Hauptman, Linear Collider Meeting, Paris, 19-23 April 2004



Signal path: calorimeter to behind yoke



Meeting, Paris, 19-23 April 2004




Si-W: 50 layers 2 mm W + 0.3 mm Si (M.Breidenbach, T.Maruyama, ...)

Strengths: known technology, fine granularity, well simulated and well understood.


Weaknesses: Si may be radiation-soft, electron-hole drift is slow; recovery time long (compared to 1.4 ns).

- Zeuthen r-φ segmentation
- Rin = 1.0 cm
- Rout = 2.0 cm





SiW dose




20 April 2004

John Hauptman, Linear Collider Meeting, Paris, 19-23 April 2004



Results from RD50: Si is OK up to 1 Grad (M. Moll, RD50/2003/001)



Most remarkable fact: oxygenated Si is impervious to electromagnetic radiation damage, i.e., OK for LC, and not OK for p's and π 's, i.e., not OK for LHC.

Si → diamond (Wolfgang Lohmann)

Table 2: Properties of Diamond, 4H-SiC, Si and GaN crystals.

Property	Diamond	4H-SiC	Si	GaN
Eg [eV]	5.5	3.27	1.12	3.39
μ_e [cm ² /Vs]	1800	800	1500	1000
μ_h [cm ² /Vs]	1200	115	450	30
e-h energy [eV]	13	8.4	3.6	~8-10
Displacem. [eV]	43	25	13-20	~10-20
Density [g/cm ³]	3.52	3.21	2.33	6.15
Radiation length X ₀ [cm]	12.2	8.7	9.4	2.7
e-h pairs / X ₀ [10 ⁶ cm ⁻¹]	4.4	4.5	10.1	~2-3



Quartz Fiber Calorimetry

(Spanier, Bugg & Onel, Winn)

Strengths: well understood (CMS-HF), fast and

radiation-hard.

Weaknesses: time spread of signal ~ 1ns (almost OK); radiation hardness ~ 1 Grad (almost OK).

"Rapunzel"




20 April 2004

John Hauptman, Linear Collider Meeting, Paris, 19-23 April 2004



CMS-HF quartz fiber Nural Akchurin, TTU

The quartz fiber Hadronic Forward (HF) calorimeter of CMS is completely understood. Energy resolution, spatial resolution, radiation damage, Cerenkov light budget at all stages, uniformity, etc.




Fast for the 25-ns LHC
Slow for the 1 4-ns warm I C




Detailed understanding of everything in HF

Cerenkov photon budget at every physical stage of this new quartz fiber calorimeter





Quartz Transmission vs. Dose & Dose Rate



Ray Thomas, Texas Tech University – using an electron accelerator


ray.thomas@ttu.edu


 $1/\lambda_{atten} = \alpha D^{\beta}$

D (MRad), $\alpha,\beta \sim 0.3$




And, at two more wavelengths








And, for each wavelength at two dose rates








Gas Cerenkov: Basic idea

• Shower particles generate Cerenkov light in gas between highly reflective metallic walls.



• Gas refractive index $n = 1 + \delta$, where $\delta \sim 0.001$ for most gases at STP.

• Cerenkov angle is small: $\sin \theta_{\bar{C}} \approx \sqrt{2\delta} \approx .05$

• Cerenkov threshold is high: $E_{th} \approx \frac{m_e}{\sqrt{2\delta}} \approx 11.2 \text{ MeV}$


• Cerenkov photons co-move with e+/- in a 15 ps pancake


Very radiation-hard: only gas and metal.

Does not "see" IP γ ,e backgrounds nor radioactivation below10-20 MeV



Hex simulation





20 April 2004

John Hauptman, Linear Collider Meeting, Paris, 19-23 April 2004



Parallel Plate Avalanche Chamber (PPAC)


(Onel, Norbeck)

- Low pressure gas, ~ 20 torr
- Plates at

~700 V

- Signal generation ~ 3 ns
- Positive ions take ~ 1 μs

PPACs are well understood and, for non-organic gases, would suffer little radiation damage.






PbWO₄ Crystals: CMS ECAL

- Well understood, tested.
- Signal generation ~ 10 ns
- Signal recovery ~ 25 ns
- QA problems during manufacture solved.
- Radiation hardness undergoing testing for time dependence of signal and signal loss.



"Study of Radiation Damage in Lead Tungstate Crystals Using Intense High Energy Beams", V.A. Batarin, et al., 5 Oct 02, hep-ex/0210011

(Note Bene: these dose rates are far below the 10 Rad/s for a LC luminosity monitor).




20 April 2004

John Hauptman, Linear Collider Meeting, Paris, 19-23 April 2004



"Study of Radiation Damage in Lead Tungstate ...", ibid., Batarin, V.A., et al.,


27 GeV e- beam





Radiation hardness: PbWO₄ compared to quartz fiber

—— 27 GeV e-Batarin, et al.



20 April 2004

John Hauptman, Linear Collider Meeting, Paris, 19-23 April 2004



Time scales (ns)

	Si-W	Quartz fiber	Gas Cerenkov	PPAC	PbWO4
Signal generation	3	~0	~0	1.65	10
Signal trans- mission	3	1	.3	5	2
Recovery time	5	2	1	1000	25
DAQ time		1	1	?	1



Radiation Hardness

	Si-W	Quartz fiber	Gas Cerenk	PPAC	PbWO4
Dose-to- Death	1 GRad	10 GRad	100 GRad	?	0.1 GRad
Signal loss per 0.1 GRad	1%	12%	1%	?	90%
Other potential signal losses	on-wafer circuitry	-	R<1.0 10%	?	?
Main weakness	defect generation	optical damage	optical transport	positive ions	optical damage



Grade A, B, ..., → F

	Si-W	Quartz fiber	Gas Cerenkov	PPAC	PbWO4
Time	В	В	A	F	С
Radiation hardness	Α	Α	A	В	F
Physics strength	Α	В	С	С	В
Risk = 1/success	В	Α	D	D	В



Necessary R&D and beam tests...

Si-W	(1) radiation damage tests – see TTU work above (2) expose a few Si layers to 1.4 ns test beam
Quartz fiber	(1) test in 1.4 ns test beam (2) test sensitivity to low energy e's in IR
Gas Cerenkov	(1) manufacture smooth metallic surfaces (2) test in 1.4 ns test beam
PPAC	(1) test multilayer PPAC in "hot" source, first. If Δt<5ns,(2) expose to 1.4 ns test beam
PbWO ₄	(1) radiation hardness at 100 MRad level – see TTU work (2) test for time scale of recovery in fast beam



Summary

- Good ideas, but any contender must be dosed (at SLAC or elsewhere) at high rate and to high dose levels.
- Proponents must produce a "dose-to-death" number. This is not easy.
- We need an estimate of the additional dose to the luminosity monitor not associated with bunch crossings.
- For the warm LC, signal generation and recovery times should allow integration over only 1-2 bunches, not more, for the critical early stages of tuning the linac beams. The luminosity made depend on bunch number ...
- Timing constraints are largely absent for the cold machine with 337 ns bunch spacing.